Table 1. Loads and outputs for heat emitters.

Living	Heat Loss	Installed	Percentage
Room	Figure	Capacity	Oversized
Front	2349	2464	5%
Room			
Kitchen	2041	2187	7%
Hall/Stairs	420	456	8%
Combined			
Bedroom 1	1692	1791	6%
Bathroom	868	980	13%
Bedroom 2	1019	1117	10%